

Fire Pump Flowmeter Systems

Fire pump flowmeters may be used to determine the discharge of a fire pump. Water from the pump is temporarily directed through the flowmeter, then to atmospheric drain or back to the water supply source.

It is important that the flowmeter not be connected directly back to the pump suction. This arrangement does not adequately test the condition of the water supply.

These flowmeters are calibrated to measure the fire pump output directly in gal/min (dm³ /min). A control valve is provided in the flowmeter line. This valve must be completely closed, except when the flowmeter is in use. Unless otherwise noted in the listing, these systems have 175 psi (1205 kPa) rated working pressure.

FS80FLFM, FS100FLFM, FS150FLFM, FS6FGFM, FS200FLFM, FS80FGFM, FS100FGFM, FS150FGFM, FS200FGFM, FS8FG ...

Firesure firepump flowmeter systems

Pump Rating, gal/min	Meter Line size, in.	Connection	Model designation
200	3	Groove	FS80FGFM
250			
300	4	Groove	FS100FGFM
450			
500		Groove	
750	6	(165/6.5" OD)	FS150FGFM
1000			
500		Groove	
750	6	(168/6.625" OD)	FS6FGFM
1000			
1250			
1500	8	Groove	FS200FGFM
2000			
2500	8	Groove	FS8FGFM
3000			
200	3	Wafer	FS80FLFM
250			
300	4	Wafer	FS100FLFM
450			
500			
750	6	Wafer	FS150FLFM
1000			
1250			
1500	8	Wafer	FS200FLFM
2000			



Rated working pressure is 290 psi (2000kPa). Meters are scaled to give readings in both GPM and dm³/min.

	InFlux Measurements Ltd		
Company Address:	1A Bennett House The Dean, Alresford Hampshire SO24 9BQ, United Kingdom		
Company Website:	http://www.influxmeasurements.com		
New/Updated Product Listing:	No		
Listing Country:	United Kingdom		
Certification Type:	FM Approved		