



## USQT.S35704 Extinguishing System Attachments

[Page Bottom](#)

### Extinguishing System Attachments

[See General Information for Extinguishing System Attachments](#)
**WEFLO VALVE CO LTD**

S35704

Intersection of Huadong Rd and Chunyang Rd  
Qingdao National High-tech Industrial Development Zone  
QINGDAO, SHANDONG 266111 CHINA

#### SPRINKLER SYSTEM ALARM INITIATING DEVICES

**Wet pipe, paddle type**

Model	Size In.	Pipe Schedule	Max System Pressure psig
F6001-50	2	10 thru 40	450
F6001-65	2.5	10 thru 40	450
F6001-80	3	10 thru 40	450
F6001-100	4	10 thru 40	450
F6001-125	5	10 thru 40	450
F6001-150	6	10 thru 40	450
F6001-200	8	10 thru 40	450

#### SUPERVISORY SIGNAL INITIATING DEVICES

**Supervisory switches**

Model	Oper Pressure psig	Max System Pressure psig
WOSY-1	N/A	N/A
WOSY-2	N/A	N/A
WOSY-3	N/A	N/A
WIP-1	N/A	N/A
WIP-2	N/A	N/A
WIP-3	N/A	N/A

[Last Updated](#) on 2016-09-07

[Questions?](#)
[Print this page](#)
[Terms of Use](#)
[Page Top](#)

© 2017 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2017 UL LLC".