

SUPPLIER'S DECLARATION OF CONFORMITY

In accordance with ISO/IEC 17050-1

Officine Rigamonti Spa

With headquarters in Valduggia 13018 (Vercelli), Via Circonvallazione 9, manufacturer of brass and bronze valves and fittings for sanitary, water and heating system use,

DECLARES

on their own responsibility that the following products:

PISTON PRESSURE REDUCING VALVE

- Art. 232 PISTON P.R.V. SABO PN16 F/F - W/ GAUGE CONNECTION NICKEL PL
- Art. 233 PISTON PRESSURE REDUCING VALVE NICKEL PLATED F/F
- Art. 236 PISTON PRV PN 25 WITH UNIONS F/F YELLOW

ARE PRODUCED

properly according to the following steps:

- ⇒ The raw material used is brass in conformity with the EN 12164 (CW614N) for brass bars and EN 12165 (CW617N) for hot pressed articles
- ⇒ The threads meet the requirements of ISO 228/1
- ⇒ The piston is made in high resistance polymer for 233 & 236, and brass EN 12164 (CW614N) for 232
- ⇒ The hermetic sealing is guaranteed thanks to the highly resistant elastomers
- ⇒ All materials used are highly resistant to temperature. They allow the use of the PRV with liquid temperatures up to 130°C, maintaining the functional features of the PRV.

ARE TESTED

in accordance with the requirements of the European Standard


- ⇒ **EN 1567 "Valves for water supply - Building valves. Water pressure reducing valves and combination water reducing valves. Requirements and tests.**

And with the supplementary requirements of Internal Standard

- ⇒ **FL.GQ.11 "Endurance tests"** with test fluid at 130°C ± 5°C

The Quality Control System of **Officine Rigamonti spa**, is certified in accordance with **ISO 9001:2008 BVQI n° 170929**. The company undertakes to provide clients with reports, tests and technical information relative to any of the above-mentioned products as and when requested, and, furthermore, puts their experience and advice at the client's disposal to ensure the correct use of their products;

Quality Manager
Musano Nicola



Valduggia, the 23rd of August 2012