



FlowCon Declaration of Conformity

Pressure Equipment Directive 97/23/EC

Date: May 2014

Manufacturer

FlowCon International ApS, Trafikcenter Allé 17, 4200 Slagelse, Denmark

Description of the pressure equipment

Pressure Independent Control Valve FlowCon SM

Type: SM.3.0, SM3.1, SM.3.2: DN50/65/80
SM.4.1, SM.4.2, SM.4.3: DN80/100

Fluid Group: 2
Temperature range: -20/+120°C
Design pressure: 40 bar

Conformity assessment followed

Category I (procedure A)

References of the harmonized Standards

EN 12516 / EN13445 / EN10204-3.1

Authorized on behalf of FlowCon International ApS

Mr. Finn Christensen
Quality and Sourcing Manager